

RMPOA  
PO Box 407  
Conway, NH 03818  
info@rockhousemountain.net  
rockhousemountain.net

## PLUMBING SPECIFICATIONS

The piping from the curb stop to the building must be  $\frac{3}{4}$ " IPS 200 PSI

Interior Water Line- IPS connector must be made of brass

The water main inside the house should also have the following:

- I. Pressure Reducing Valve
- II. Backflow prevention device (Watts EJP52035)
- III. Water meter and equipment (Available for purchase through RMPOA):
  - a. Neptune brand meter (5/8")
  - b. 5/8" kornhorn
  - c. Neptune reader button